

Government of Bihar
Public Health Engineering Department
Water Quality Report

District:Katihar

Water sample are given by- Staff of School

Water sample Receiving Date-06-04-2021 in Lab.

SL. NO	Pan chayat	Name of the village.	Village Code.	Population (2001)	Name of the Habitation.	Nearest Person.	NTU		P.H	Conductivity	Total Hardness	Total Alkainity	Chloride	Iron	Calcium	Magnesium	Nitrate	T.D.S.	As	F
							Turbidity													
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	
	Sutara Mehi Mission School Sureshwar Nagar, Devipur, kursela, Distt. katihar						2	7.31	384	240	240	40	0.42	80	29	5	250	BDL	-	
BIS: 10500:2012 (Second revision)							1	6.5-8.5	-	200	150	250.0	1.00	75	30	45.00	500	0.01	1	
Permissible limit in absence of alternate source							5	NR	-	600	400	1000.0	NR	200	100	NR	2000.0	NR	1.5	

Asst. Eng. Kesari
Signature of Lab. Assistant
08-04-2021

g.m.s.
Signature of Chemist
08-04-2021

Asst. Eng. Sub. Div. Katihar
Assistant Engineer
P.H. Sub-Div. Katihar
08/04/21

Asst. Eng. Sub. Div. Katihar
Executive Engineer
P.H. Div. Katihar
08/04/21